


North Las Vegas Building and Fire Safety Fire Plan Review

Kitchen Hood Suppression System Checklist

This example illustrates the minimum information required for plan submittal for Type I Hood Fire Hood Suppression System



NOTE: Used the 1/2004 issue of Brand X design manual. Total nozzle flow pt. count = 12, Total flow pt. count allowed = 14

(1)

(2-flow pts)

23388

Groove grid

Appliance pipe = 3/4"pipe, 22" plus 6" equivalent lengtr Appliance pipe = 1/2" pipe, 14.5' plus 3.2' equiv. length Plenum pipe = 3/8" pipe, 12' plus .5' equiv. length Duct pipe = 1/2" pipe, 3.5' plus 1' equiv. length Pipe volume calculations and total are detailed.